

# SCBA Maintenance Log

Manufacturer: \_\_\_\_\_

Regulator Serial Number: \_\_\_\_\_

Tank Serial Number: \_\_\_\_\_

Visual Inspection													
<b>Month/Year:</b> (MM/YYYY)													
<b>Rate the following:</b>													
<b>Valve:</b>	Good	Bad	Good										
<b>Tubes:</b>	Good	Bad	Good										
<b>Tank:</b>	Good	Bad	Good										
<b>Regulator:</b>	Good	Bad	Good										
<b>Pressure Gauge:</b>	Good	Bad	Good										
<b>Any signs of:</b>													
<b>Deterioration:</b>	Yes	No	Yes										
<b>Rust:</b>	Yes	No	Yes										
<b>Corrosion:</b>	Yes	No	Yes										
<b>Dents:</b>	Yes	No	Yes										
<b>Cut or Tears:</b>	Yes	No	Yes										
<b>Is pressurization check completed without issue?</b>	Yes	No	Yes										
<b>Is the tank air at least 90%?</b>	Yes	No	Yes										
<b>Are the regulator and warning devices working properly?</b>	Yes	No	Yes										
<b>Comments:</b>													
<b>Date of Inspection:</b>													
<b>Name of Inspector:</b>													
<b>Signature of Inspector:</b>													

- Posi-check testing due every 2 years
- Hydrostatic testing due every 5 years
- Cylinders need replacement every 15 years